



2820 S. English Station Road - Louisville, KY 40299  
 Tel: (502) 357-0132 Fax (502) 267-8379

Date: 4/6/2020 TEST NO. 20-181-1

# Respirator Media Test Report

Following NIOSH Procedures TEB-APR-STP 0051-0059  
 and CFR 42 Part 84 Subpart K-Non-Powered Air Purifying Particulate  
 Respirators

## Filter Description

|                            |                           |
|----------------------------|---------------------------|
| Manufacturer               | DHA Filter                |
| Filter Model               | N/A                       |
| Part Number                | FM-99-D                   |
| Generic Filter Type        | PP Nonwoven Mask Material |
| Nominal Dimensions (H x W) | N/A                       |
| Pocket / Pleat Quantity    | N/A                       |
| Media Type                 | PP Nonwoven/PTFE membrane |
| Est. Gross Media Area      | N/A                       |

## Test Conditions

|                               |               |                            |    |
|-------------------------------|---------------|----------------------------|----|
| Test Aerosol                  | Latex Spheres | Test Air Temp (degrees F.) | 75 |
| Barometric Pressure (In. Hg.) | 29.4          | Relative Humidity (%)      | 46 |


## Test Results

|                                     |           |
|-------------------------------------|-----------|
| Airflow Rate (CFM)                  | 1.3       |
| Nominal Face Velocity (FPM)         | 3.0       |
| Test Area (ft <sup>2</sup> )        | 0.431     |
| Average Initial Resistance (in. WG) | 0.04      |
| Average Efficiency at 0.1 µm (%)    | 99.49     |
| Rating                              | Not Rated |

**Comments** Tested on VD2 using Aerosolized Latex Spheres and TSI Model 3080 Electrostatic Classifier and TSI Model 3772 Particle Counter. Efficiency calculated for particles at 0.1µm at 1.3 CFM (85L/min) using a 0.43 ft<sup>2</sup> test area.  
 Average values are taken for the three independently run tests on the designated media.  
 Individual test results found on page two.

|                                  |                    |   |                 |  |
|----------------------------------|--------------------|---|-----------------|--|
| <b>Requestor Information</b>     | Test Requestor     | Jeff Hanna                              | Phone:          | 904-269-8701   |
|                                  | Company Name       | DHA Filter                              | Email:          | <a href="mailto:jeff@dhafilter.com">jeff@dhafilter.com</a> |
|                                  | Company Address    | P.O. Box 66209 Orange Park, FL<br>32065 | Date Requested  | 4/1/2020   |
| <b>Test Operator Information</b> | Test Performed by: | Evan Sparks                             | Completion Date | 4/6/2020   |

### Removal Efficiency vs. Particle Size



**Blue Heaven Technologies**2820 S. ENGLISH STATION ROAD - LOUISVILLE, KY 40299  
Tel: (502) 357-0132**Respirator Media  
Test Report**

Single Pass Tests

Test No. 20-181-1

Date: 06-Apr-20

**Data - Initial Resistance**

| Velocity<br>(FPM) | Initial Resistance (in. WG) |          |          |         |
|-------------------|-----------------------------|----------|----------|---------|
|                   | Sample 1                    | Sample 2 | Sample 3 | Average |
| 3.00              | 0.04                        | 0.04     | 0.04     | 0.04    |

| Velocity<br>(FPM) | Initial Resistance (Pa) |          |          |         |
|-------------------|-------------------------|----------|----------|---------|
|                   | Sample 1                | Sample 2 | Sample 3 | Average |
| 3.00              | 9.96                    | 9.96     | 9.96     | 9.96    |

**Data - Particle Removal Efficiency**

| Particle<br>Size<br>( $\mu$ m) | Efficiency % |          |          |         |
|--------------------------------|--------------|----------|----------|---------|
|                                | Sample 1     | Sample 2 | Sample 3 | Average |
| 0.1                            | 99.23        | 99.77    | 99.46    | 99.49   |